

YDEEVNEDEKLARATION / DECLARATION OF PERFORMANCE

**I henhold til / According to Construction Products Regulation EU N° 305/2011 DoP no.:
100231 (GNS-2236RF)**

1. Varetypens unikke identifikationskode:

LIFE Røgalarm 230 volt trådløs model 100231 (GNS-2236RF)

2. Type-, parti- eller serienummer eller en anden form for angivelse, ved hjælp af hvilken byggevaren kan identificeres som krævet i henhold til artikel 11, stk. 4:

LIFE RØGALARM 230 volt trådløs

3. Byggevarens tilsigtede anvendelse eller anvendelser i overensstemmelse med den gældende harmoniserede tekniske specifikation som på tænkt af fabrikanten:

Røgalarm til anvendelse i privat beboelse (Fire safety – Domestic smoke alarm)

4. Fabrikantens navn, registrerede firmabetegnelse eller registrerede varemærke og kontaktadresse som krævet i henhold til artikel 11, stk. 5:

Foss Europe A/S, Wichmandsgade 5E, 5000 Odense C, Danmark

5. I givet fald navn og kontaktadresse på den bemyndigede repræsentant, hvis mandat omfatter opgaverne i artikel 12, stk. 2:

Ikke anvendelig

6. Systemet eller systemerne til vurdering og kontrol af konstansen af byggevarens ydeevne, jf. bilag V:

System 1

7. Hvis ydeevnedeklarationen vedrører en byggevare, der er omfattet af en harmoniseret standard:

EN 14604:2005/AC:2008 Røgalarm (smoke alarm device)

Det notificerede produktcertificeringsorgan udsteder attesten for byggevarens ydeevnes konstans på grundlag af: bestemmelse af varetypen på grundlag af typeprøvning (herunder stikprøveudtagning), typeberegning, tabelværdier eller deskriptiv dokumentation for byggevaren; indledende inspektion af fabriksanlæg og fabrikkens egen produktionskontrol; kontinuerlig overvågning, vurdering og evaluering af fabrikkens egen produktionskontrol. Efter system 1 og udstedte:

Nodified body nr. 0086 - BSI Assurance UK Ltd., Kitemark Court, Davy Avenue, Knowlhill, Milton Keanes, MK5 8PP, United Kingdom

8. Hvis ydeevnedeklarationen vedrører en byggevare, for hvilken der er udstedt en europæisk teknisk vurdering:

Ikke anvendelig (se 7)

9. Deklareret ydeevne: Fremgår af appendix 1 nedenfor

Certificate of Constancy of Performance

No. 0086-CPR-638573

Appendix 1

Harmonised Technical Specification		EN 14604:2005
Essential Characteristics	Performance	Clause
Nominal activation conditions / sensitivity / response delay (response time) and performance under fire conditions		
Smoke alarm signals	Pass	4.12
Repeatability	Pass	5.2
Directional dependence	Pass	5.3
Initial sensitivity	Pass	5.4
Air movement	Pass	5.5
Dazzling	Pass	5.6
Fire sensitivity	Pass	5.15
Sound output	Pass	5.17
Sounder durability	Pass	5.18
Alarm silence facility	Pass	5.20
Operational Reliability		
Compliance	Pass	4.1
Individual alarm indicator	Pass	4.2
Mains on indicator	Pass	4.3
Connection of external ancillary devices	Pass	4.4
Means of calibration	Pass	4.5
User replaceable components	Pass	4.6
Normal power source	Pass	4.7
Standby power source	Pass	4.8
Electrical safety requirements	Pass	4.9, 5.24
Routine test facility	Pass	4.10
Terminals for external conductors	Pass	4.11
Battery removal indication	Pass	4.13
Battery connections	Pass	4.14

First Issued: 2015-06-24

Latest Issue: 2018-03-19

Page: 4 of 5

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.
To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

BSI Assurance UK Limited, registered in England under number 7805321 at 389 Chiswick High Road, London W4 4AL, UK.
A member of BSI Group of Companies.

Certificate of Constancy of Performance

No. 0086-CPR-638573

Appendix 1 (continued)

Harmonised Technical Specification		EN 14604:2005
Essential Characteristics	Performance	Clause
Operational Reliability		
Battery capacity	Pass	4.15
Protection against the ingress of foreign bodies	Pass	4.16
Marking and data	Pass	4.19
Impact	Pass	5.11
Battery fault warning	Pass	5.16
Battery reversal	Pass	5.22
Backup power source	Pass	5.23
Tolerance to supply voltage		
Variation in supply voltage	Pass	5.21
Durability of Operational Reliability		
Dry heat	Pass	5.7
Cold (operational)	Pass	5.8
Damp heat (operational)	Pass	5.9
Sulphur dioxide (SO ₂) corrosion	Pass	5.10
Vibration (operational)	Pass	5.12
Vibration (endurance)	Pass	5.13
Durability of Operational Reliability, Electrical Stability		
Electromagnetic compatibility (EMC), immunity (operational)	Pass	5.14

First Issued: 2015-06-24

Latest Issue: 2018-03-19

Page: 5 of 5

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.
To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

BSI Assurance UK Limited, registered in England under number 7805321 at 389 Chiswick High Road, London W4 4AL, UK.
A member of BSI Group of Companies.

DA 10. Ydeevnen for den byggevare, der er anført i punkt 1 og 2, er i overensstemmelse med den deklarerede ydeevne i punkt 9. Denne ydeevnedeklaration udstedes på eneansvar af den fabrikant, der er anført i punkt 4. Underskrevet for fabrikanten og på dennes vegne af:



Klavs Larsen

Direktør

(navn og stilling)

Odense, Danmark 2018-05-20

(sted og dato)